

CERTIFICATE OF ANALYSIS

CERTIFICATE NO. 1033095.1A

CUSTOMER REF. PO: 47000

SAMPLE DETAILS

DATE RECEIVED 28-Jun-17

Wallcoverings

METHOD: (Determination of Susceptibility of Materials to Fungal growth using ASTM G21

DATE ANALYSED 17-Jul-17

DATE REPORTED 15-Aug-17

SAMPLE

Growth Rating
Average

IMSL Reference (Filter Paper)	4.0
Non-Woven Fabric Backed Vinyl Wallcovering (Batch 129804)	1.0

Inoculum:	<i>Aspergillus niger</i>	ATCC 9642
	<i>Paecilomyces variotti</i>	ATCC 18502
	<i>Chaetomium globosum</i>	ATCC 6205
	<i>Gliocladium virens</i>	ATCC 9645
	<i>Aureobasidium pullulans</i>	ATCC 15233

Key:	No growth apparent under magnification
	1 Traces of growth (less than 10%)
	2 Light growth (10 - 30%)
	3 Medium growth (30 - 60%)
	4 Heavy Growth (60% to complete coverage)

INDUSTRIAL MICROBIOLOGICAL SERVICE LTD
PALE LANE
HARTLEY WINTNEY
HANTS
RG27 8DH
UK